

Clear away nearby vegetation and trim any branches hanging over the building or within 3 meters of the smoke outlet.

REGULAR MAINTENANCE

Clean spark arrestor meshes regularly to prevent blockages and replace them if needed.

ALWAYS HAVE QUICK ACCESS TO WATER (BUCKET, TANK, OR WATER SUPPLY) NEAR FIRE-PRONE AREAS

IF YOU OWN OR MANAGE A TOURIST ACCOMMODATION SHARE FIRE SAFETY RULES

Place signs in key areas like barbecues, fireplaces, and entrances.

Include fire safety guidelines on your website and in house rules.

BARBECUES, FIREPLACES, AND OPEN FLAMES

Before lighting a fire, check the fire risk level at www.112cv.com or @GVA112. If Level 3 is declared, all fires (including camping stoves) are strictly prohibited.

Only cook in designated areas.

Make sure embers are fully extinguished before leaving, and never transport hot ashes or coals.

CIGARETTES, MATCHES, AND FLAMMABLE MATERIALS

Never discard cigarette butts or matches on the ground—fully extinguish them and use proper disposal bins.

Fireworks, sky lanterns, and any open flames are strictly forbidden near forests.

WASTE DISPOSAL & SURROUNDING AREA

Never leave trash in the forest or surrounding areas—it increases fire risk.

Keep the area clean and free from dry leaves, branches, and other flammable debris.

SAFE PARKING

Park only in designated areas and keep emergency access routes clear.

Always park facing the exit to allow for quick evacuation if needed.



¿PARTE DEL PROBLEMA O PARTE DE LA SOLUCIÓN?

MEDIDAS DE SEGURIDAD PARA LA PREVENCIÓN DE INCENDIOS FORESTALES



ARE YOU PART OF THE PROBLEM OR PART OF THE SOLUTION?

FIRE PREVENTION MEASURES





ADECUA TODOS LOS PUNTOS DE FUEGO (PAELLEROS, CHIMENEAS, ETC.).

Los paellers y barbacoas situados en las parcelas privadas de las urbanizaciones deben contar con un techado y estar cubiertos a 3 vientos mediante paramentos cerrados de suelo a techo, que lateralmente abarquen al menos la zona de fuegos y 1 metro adicional a partir de este.

Red matachispas de material no inflamable y con abertura de malla entre 0,5 y 1 cm, obligatoria en todas las salidas de humo. Se recomienda la instalación de una caperuza matachispas adicional en chimeneas para reforzar la seguridad.

Elimina la vegetación cercana y retira las ramas que dominen la construcción o queden a menos de 3 metros de la salida de humos.

MANTENIMIENTO PERIÓDICO

Limpia las redes matachispas con regularidad para evitar obstrucciones o reemplázalas en caso de necesidad.

ASEGÚRATE DE TENER ACCESO RÁPIDO A AGUA (CUBO, DEPÓSITO O TOMA DE AGUA) CERCA DE LAS INSTALACIONES DE FUEGO

USO DE BARBACOAS, CHIMENEAS Y PAELLEROS

Consulta el nivel de preemergencia de incendios en www.112cv.com o @GVA112. En caso de decretarse el Nivel 3, está totalmente prohibido encender fuego (incluyendo camping gas).

Cocina solo en áreas habilitadas.

Apaga completamente los rescoldos antes de abandonar la zona y no traslades brasas, cenizas o restos calientes.

COLILLAS, FÓSFOROS Y MATERIALES INFLAMABLES

No tires colillas ni fósforos al suelo. Apágalos bien y deposítalos en un contenedor adecuado.

Prohibido lanzar petardos, farolillos u objetos en llamas cerca de zonas forestales.

GESTIÓN DE RESIDUOS Y ENTORNO

No dejes basura en el monte ni en áreas cercanas. Los residuos aumentan el riesgo de incendio.

Mantén el entorno limpio y libre de material inflamable como hojas secas y ramas.

SI ERES PROPIETARIO O GESTOR DE UN ALOJAMIENTO TURÍSTICO DIFUNDE LAS NORMAS DE PREVENCIÓN

Coloca carteles en puntos clave de la propiedad: paellero, chimenea, entradas, etc.

Incluye las recomendaciones en la web del alojamiento y en el reglamento interno.

APARCAMIENTO SEGURO

Aparca solo en zonas habilitadas y no obstruyas caminos de acceso para emergencias.

Estaciona en dirección a la salida para facilitar evacuaciones.



PREPARE ALL FIRE AREAS (BARBECUES, CHIMNEYS, ETC.)

Paella burners and barbecues on private plots within residential developments must be covered with a roof and enclosed on three sides with solid walls from floor to ceiling. The enclosure should cover the cooking area and extend at least one meter beyond it for safety.

Install a non-flammable spark arrestor mesh with openings between 0.5 and 1 cm on all smoke outlets. For added safety, consider installing an extra spark arrestor cap on chimneys.